

NSF/ANSI STANDARD 60

Drinking Water Treatment Chemicals - Health Effects

SPICER RANDOLPH LLC

9179 WEST FLAMINGO ROAD
SUITE 110
LAS VEGAS, NV 89147
913-205-4773

Facility : # 2 USA

Sodium Hypochlorite [CL]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Neutral Bleach	Corrosion & Scale Control	[1]
	Sequestering	
Oxide	Corrosion & Scale Control	[2]
	Sequestering	
RE-Ox	Corrosion & Scale Control	[1]
	Sequestering	

[1] This product can be used at or up to 17,500 mg/L.

[2] This product can be used at or up to 35,000 mg/L.

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.