



June 22, 2005

Mr. Lawrence McLeroy
Earth Science Laboratories, Inc.
515 Brown Street
P.O. Box 710
Holdrege, NE 68949

Dear Mr. McLeroy:

This letter acknowledges that NSF *International* has Certified the products below to NSF/ANSI Standard 60 for Earth Science Laboratories, Inc.:

Product Name: Earth Tec
Plant Location: Holdrege, NE
Chemical Category: Miscellaneous Treatment Applications
Use Category: Algicide
Maximum Use: 19 mg/L

Earth Science Laboratories, Inc. and these products are Certified and are authorized to bear the NSF Mark. As long as Earth Science Laboratories, Inc. maintains these product Listings, the products will also appear in NSF's on-line Listings display at www.nsf.org (updated daily) and in routine publications of the NSF Drinking Water Additives Listing Book.

This letter may be copied and distributed only in its entirety. For confirmation of the current status, please contact NSF directly at 734-769-8010.

Sincerely,

A handwritten signature in blue ink that reads "BU Stark".

K. Blake Stark
Business Unit Manager
Water Treatment Chemicals
Phone: 734-769-5480
Fax: 734-769-0109



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on July 21, 2005.

EARTH SCIENCE LABORATORIES, INC.
515 BROWN STREET
P.O. BOX 710
HOLDREGE, NE 68949
308-995-2271

Facility: HOLDREGE, NE

Table with 3 columns: Chemical/Trade Designation, Function, and Max Use. Rows include Agritec, Earth Tec, and Pristine Blue with their respective functions and maximum use concentrations.

[CP] The finished drinking water shall be monitored to ensure that levels of copper do not exceed 1.3 mg/L.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.



Live safer.™

Close w/
exit NSF

NSF Product and Service Listings


These Listings were Last Updated on **Tuesday, August 09, 2005** at 4:15 AM Eastern Time. Please contact NSF International to confirm the status of any Listing, report errors, or make suggestions.

Warning: NSF is concerned about fraudulent downloading and manipulation of website text. If you have received this listing in hard copy, always confirm this certification/listing information by going directly to <http://www.nsf.org/Certified/PwsChemicals/Listings.asp?CompanyName=earth+science&> for the latest most accurate information.

NSF/ANSI STANDARD 60 Drinking Water Treatment Chemicals - Health Effects

EARTH SCIENCE LABORATORIES, INC.

515 BROWN STREET
P.O. BOX 710
HOLDREGE, NE 68949
308-995-2271



Facility : HOLDREGE, NE

Miscellaneous Treatment Applications[CP]

<i>Trade Designation</i>	<i>Product Function</i>	<i>Max Use</i>
Agritec	Algicide	19 mg/L
	Bactericide	
Earth Tec	Algicide	19 mg/L
	Bactericide	
Pristine Blue	Algicide	19ml/L
	Bactericide	

[CP] The finished drinking water shall be monitored to ensure that levels of copper do not exceed 1.3 mg/L.

Number of matching Manufacturers is 1
Number of matching Products is 3
Processing time was 0 seconds